

## Appendix B

### Certified Validation Report Template, Part A: Provided by Validator

**Audit Information:**

Water Supplier Name: Scotts Valley Water District      PWS ID:4410013

System Type: Potable      Audit Period: Calendar 2018

Utility Representation: David McNair (Operations Manager)

Validation Date:9/19/2019      Call Time: 12:00PM      Sufficient Supporting Documents Provided: Yes

**Validation Findings & Confirmation Statement:****Key Audit Metrics:**

Data Validity Score:60      Data Validity Band (Level): Band III (51-70)

ILI: 0.76      Real Loss: 17.88 gallons/connection/day      Apparent Loss: 2.76 gallons/connection/day

Non-revenue water as percent of cost of operating system: 1.6%

**Certification Statement by Validator:**

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☐

*If not, rejected recommendations are included here.*

**Validator Information:**

Water Audit Validator: Tanmay Thakur from Nobel Systems. Qualifications: Water Audit Validator Certificate issued by the CA- NV Section of the AWWA

## Certified Validation Report Template, Part B: Provided by Utility

**Water Supplier Name:**

**Water Supplier ID Number:**

**Water Audit Period:**

**Water Audit & Water Loss Improvement Steps:**

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

1. Implemented customer meter testing for more accurate Customer meter inaccuracy reports.
2. AMI meter replacements were conducted and meters with low accuracy replaced on customer complaints.

**Certification Statement by Utility Executive:**

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

**Executive Name (Print)**


**Executive Position**

**Signature**

**Date**

David McNair

Operations Manager



9/16/21

Utility Provided